

# City of Baltimore Wet Weather Consent Decree Smoke and Dyed Water Testing Form

Page 1 of 1

Sewershed: Gwynns Falls

Company: Savin

Date: 4/21/2009

Test to be performed:

Smoke ☐ Dyed Water ☒

Ground Condition:

Dry ☒ Damp ☐ Wet ☐

Supervisor: JAW


Manhole\_ID: S01SS\_003MH

Test ID: D1032-022029

Notification Made: NA

(Residents, Fire, 311)

Field Sketch: Show all manholes with Numbers, Blower Placement Locations, Sandbag or Isolation Locations, Street Names, Building Addresses and Locations, Defect Locations and Photo Numbers.



Defect Loc	Obs_ClockFrom	Obs_ClockTo	Observation	Obs_Remarks
0			Start of Survey	
0			Manhole	S01SS_003MH
0			Water Level	
3			General Observation	OUTSIDE DROP CONN
16.79999924			Dye Test Visible	@ IR, 1 GPM
16.79999924	10		Infil Runner	@ jt
16.79999924			Water Level Sag	
25.70000076			Water Level Sag	
25.89999962			Abandoned Survey	NO MORE DYE SEEN